

## Previous Data on the Radiation Level of Purified Water at Water Purification Plants in Tama Area in September

Since August 1<sup>st</sup> 2011, purified water at Purification Plants in Tama area has been tested at Water Quality Management Center.

### 1 Tachikawasunagawa Purification Plant (groundwater)

Address: 6-41-1, Sunagawa-cho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/1	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2011/9/29	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )

### 2 Nakato Water Supplying Station (groundwater)

Address: 2-1-3, Nakato, Musasimurayama city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/1	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )
2011/9/29	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

### 3 Tachikawasakaecho Purification Plant (groundwater)

Address: 5-38-5, Sakae-cho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/1	ND (Detection Limit 0.9 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )
2011/9/29	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )

### 4 Shibakubo Purification Plant (groundwater)

Address: 5-9-1, Shibakubo, Nishitokyo city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/2	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2011/9/30	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

### 5 Kamikitadai Purification Plant (groundwater)

Address: 1-801-1, Kamikitadai, Higashiyamato city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/2	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )
2011/9/30	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

### 6 Takiyama Purification Plant (groundwater)

Address: 6-1-1, Takiyama, Higashikurume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/2	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )
2011/9/30	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**7 Chigasedaini Purification Plant (subsoil water)**

Address: 1-69-1, Chigasemati, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/5	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )

**8 Mitakesann Purification Plant (subsoil water)**

Address: 179-2,Mitakesann, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/5	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**9 Kamirenjyaku Purification Plant (groundwater)**

Address: 9-41-4, Kamirenjyaku, Mitaka city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/6	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )

**10 Kamiishihara Purification Plant (groundwater)**

Address: 1-34,Kamiishihara,Chofu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/6	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**11 Mitakashinkawa Purification Plant (groundwater)**

Address: 2-1-15,Shinkawa,Mikata city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/6	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**12 Yahoo Purification Plant (groundwater)**

Address: 1462-1, Yahoo, Kunitachi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/7	ND (Detection Limit 0.6 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**13 Fuchumusashidai Purification Plant (groundwater)**

Address: 2-7,Musashidai, Fuchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/7	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**14 Kunitachinaka Purification Plant (groundwater)**

Address: 3-8-1,Naka, Kunitachi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/7	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )

**15 Misawa Purification Plant (groundwater)**

Address: 1-19-1,Misawa, Hino city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/8	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**16 Osakaue Purification Plant (groundwater)**

Address: 1-17-11,Osakaue, Hino city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/8	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )

**17 Minamidaira Purification Plant (groundwater)**

Address: 2-24-5,Minamidaira, Hino city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/8	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**18 Saiwaimachi Purification Plant (groundwater)**

Address: 2-24, Saiwai-cho, Huchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/9	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**19 Jyosuiminami Purification Plant (groundwater)**

Address: 3-12-36, Jyosuiminami-cho, Kodaira city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/9	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**20 Sakuragaoka Purification Plant (groundwater)**

Address: 4-10, Sakuragaoka, Tama city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/9	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**21 Izumihoncho Purification Plant (groundwater)**

Address: 4-6-4,Izumihon-cho, Komae city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/12	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )

**22 Kamiyotsugi Purification Plant (groundwater)**

Address: 407, Kamiyotsugi, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/12	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**23 Hussamusashinodai Purification Plant (groundwater)**

Address:2- 32, Musashinodai, Husa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/12	ND (Detection Limit 0.9 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )

**24 Ogouchi Purification Plant (Tamagawa River)**

Address:1310-10,Tozura-aza-Amefuri,Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/13	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**25 Sawaidaiichi Purification Plant (subsoil water)**

Address: 1-535-3,Sawai, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/13	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )

**26 Sawaidaini Purification Plant (subsoil water)**

Address: 3-667,Sawai,Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/13	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**27 Omaru Purification Plant (groundwater)**

Address: 760,Omaru,Inagi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**28 Kajino Purification Plant (groundwater)**

Address: 5-10-33,kajinocho, Koganei city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/14	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**29 Nippara Purification Plant (Tamagawa River)**

Address: 1055-5,Nippara-aza- Ogawa, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/14	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )

**30 Wakamatsu Purification Plant (groundwater)**

Address: 4-10,Wakamatsucho, Fuchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/15	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**31 Fuchuminamicho Purification Plant (groundwater)**

Address: 1-50,Minami-cho, Fuchu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/15	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**32 Sakahama Purification Plant (groundwater)**

Address: 816,Sakahama,Inagi city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/15	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**33 Hoyacho Purification Plant (groundwater)**

Address: 1-5-24,Hoya-cho,Nishitokyo city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/16	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**34 Shibasaki Purification Plant (groundwater)**

Address: 1-1-41,Shibasakicho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/16	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**35 Minamisawa Purification Plant (groundwater)**

Address: 3-9-21,Minamisawa,Higashikurume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/16	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**36 Nishitokyosakaecho Purification Plant (groundwater)**

Address: 2-7-6,Sakae-cho, Nishitokyo city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/19	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**37 Tokura Purification Plant (Tamagawa River)**

Address: 261-2,Tokura, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/19	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**38 Fukasawa Purification Plant (Tamagawa River)**

Address: 560-6,Fukasawa, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/19	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**39 Otaba Purification Plant (Tamagawa River)**

Address: 498,Otaba-aza-Okunakachaya, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/20	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**40 Futamatao Purification Plant (subsoil water)**

Address: 5-51-1,Futamatao, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/20	ND (Detection Limit 0.9 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**41 Tanasawa Purification Plant (Tamagawa River)**

Address: 583-5, Tanasawa-aza-kashiwanoki, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/20	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**42 Fujimidaichi Purification Plant (groundwater)**

Address: 1-27-12, Fujimi-cho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/21	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )

**43 Fujimidaisan Purification Plant (groundwater)**

Address: 6-70, Fujimicho, Tachikawa city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/21	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**44 Ottsu Purification Plant (Tamagawa River)**

Address: 1464-2, Ottsu, Akiruno city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/21	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**45 Jindaiji Purification Plant (groundwater)**

Address: 5-56 Jindaijiminami-cho, Chofu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/22	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )

**46 Akatsukicho Purification Plant (groundwater)**

Address: 1-7-12, Akatsukicho, Hachioji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/22	ND (Detection Limit 0.8 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**47 Senkawa Purification Plant (groundwater)**

Address: 3-6, Senkawa, Chofu city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/22	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 1 )

**48 Ogawa Purification Plant (groundwater)**

Address: 1-847-2, Ogawa-cho, Kodaira city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/23	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )

**49 Kokubunjikitamachidaini Purification Plant (groundwater)**

Address: 4-1-51, Kitamachi, Kokubunji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**50 Higashikoigakubo Purification Plant (groundwater)**

Address: 2-5-8,Higashikoigakubo,Kokubunji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/23	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**51 Takatsuki Purification Plant (subsoil water)**

Address: 400, Takatsuki-cho, Hachioji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/26	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 1 )

**52 Hikawa Purification Plant (Tamagawa River)**

Address: 316,Hikawa-aza- ohikawa, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/26	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**53 Himura Purification Plant (Tamagawa River)**

Address: 47,Sakai-aza- Himura, Okutama town

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/26	ND (Detection Limit 0.9 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )

**54 Motohongo Purification Plant (groundwater)**

Address: 4-19-1,Motohongo, Hachioji city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/27	ND (Detection Limit 0.9 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.9 )

**55 Hinatawada Purification Plant (subsoil water)**

Address: 2-370,Hinatawada,Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/27	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**56 Nariki Purification Plant (subsoil water)**

Address: 7-1591-3,Nariki, Oume city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/27	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )

**57 Takinosawa Purification Plant (groundwater)**

Address: 2-7-7, Asahi-cho, Machida city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/28	ND (Detection Limit 0.7 )	ND (Detection Limit 0.7 )	ND (Detection Limit 0.8 )

**58 Haramachida Purification Plant (groundwater)**

Address: 5-13-3,Haramachida,Machida city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/28	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )	ND (Detection Limit 0.8 )

**59 Noduta Purification Plant (groundwater)**

Address: 3398,Nodutamachi, Machida city

Unit : Bq/kg

Sampling Date	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium ( Cesium 134 )	Radioactive Cesium ( Cesium 137 )
2011/9/28	ND (Detection Limit 0.8 )	ND (Detection Limit 0.9 )	ND (Detection Limit 2 )

1 Testing institute: Water Quality Management Center

2 ND (Not detectable): “Detection Limit” refers to the minimum detectable value. Radioactivity has the property wherein even using the same measurement device, the minimum level varies with the sample being measured. For example, a result of “ND (Detection Limit 0.8)” at X Purification Plant on a specific date means that the minimum measurement for that day’s sample was 0.8 Bq/kg, but the concentration of radioactive particles in the sample was less than 0.8 Bq/kg. Cases such as this are listed in the above chart as “ND”.

**【Reference】**

(Bq/kg)

	Radioactive Iodine ( Iodine 131 )	Radioactive Cesium
Japanese provisional (emergency) criteria for infants	100	Not specified
Japan provisional (emergency) criteria for all except infants *1	300	200

\*1 Criteria value related to radioactive elements ingestion from food and drink set by Nuclear Safety Commission